

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

1021 NORTH GRAND AVENUE EAST, P.O. BOX 19276, SPRINGFIELD, ILLINOIS 62794-9276, 217-782-3397 JAMES R. THOMPSON CENTER, 100 WEST RANDOLPH, SUITE 11-300, CHICAGO, IL 60601, 312-814-6026

ROD R. BLAGOJEVICH, GOVERNOR

RENEE CIPRIANO, DIRECTOR

217/785-0561

June 7, 2005

CERTIFIED MAIL # 7004 2510 0001 8653 1351 RETURN RECEIPT REQUESTED

Peter E. Kolb 650 Winchester Rd. Libertyville, IL 60048

Re:

Violation Notice: HAWTHORN WOODS

Facility No.: IL0970450

Violation Notice No.: W-2005-00296

Dear Mr. Kolb:

This constitutes a Violation Notice pursuant to Section 31(a)(1) of the Illinois Environmental Protection Act, 415 ILCS 5/31(a)(1), and is based upon review of available information and investigation by representatives of the Illinois Environmental Protection Agency ("Illinois EPA").

The Illinois EPA hereby provides notice of violations of environmental statutes, regulations or permits as set forth in Attachment A to this letter. Attachment A includes an explanation of the activities that the Illinois EPA believes may resolve the specified violations, including an estimate of a reasonable time period to complete the necessary activities. However, due to the nature and seriousness of the violations cited, please be advised that resolution of the violations may also require the involvement of a prosecutorial authority for purposes that may include, among others, the imposition of statutory penalties.

A written response, which may include a request for a meeting with representatives of the Illinois EPA, must be submitted via certified mail to the Illinois EPA within 45 days of receipt of this letter. The response must address each violation specified in Attachment A and include for each, an explanation of the activities that will be implemented and the time schedule for the completion of each activity. Also, if a pollution prevention activity will be implemented, indicate that intention in any written response. The written response will constitute a proposed Compliance Commitment Agreement ("CCA") pursuant to Section 31 of the Act. The Illinois EPA will review the proposed CCA and will accept or reject the proposal within 30 days of receipt.

If a timely written response to this Violation Notice is not provided, it shall be considered a waiver of the opportunity to respond and meet, and the Illinois EPA may proceed with a referral to the prosecutorial authority.

JUN 1 0 2005

LAKE COUNTY
PUBLIC WORKS

RECEIVED

Page 2 of 2 HAWTHORN WOODS VN W-2005-00296

Written communications should be directed to BEVERLY BOOKER at the ILLINOIS EPA, BUREAU OF WATER, CAS #19, P.O. BOX 19276, SPRINGFIELD, ILLINOIS 62794-9276. All communications must include reference to this Violation Notice number, W-2005-00296.

Questions regarding this Violation Notice should be directed to Jay Timm at 217/785-0561.

Sincerely,

Michael S. Garretson, Manager Compliance Assurance Section

Bureau of Water

Attachment

cc: Michael Miller Terry W. Jarrett

ATTACHMENT A

HAWTHORN WOODS, IL0970450 VIOLATION NOTICE NO. W-2005-00296:

Questions regarding the violations identified in this attachment should be referred to Jay Timm at (217) 785-0561.

A review of information available to the Illinois EPA indicates the following violations of statutes, regulations, or permits. Included with each type of violation is an explanation of the activities that the Illinois EPA believes may resolve the violation including an estimated time period for resolution.

Drinking Water Chlorination

All public water supplies must continuously chlorinate all water discharged to the distribution system. Compliance with this is expected to be achieved within 90 days by obtaining permits for and installing chlorination equipment.

Violation Date	Violation Description	
03/01/05 Rule/Reg.	Failure to provide chlorination (on-going violation) Section 18 of the Act 415 ILCS 5/18, 35 Ill. Adm. Code 601.10 653.604.	01,